## **Propane Heaters**

Facility:	Written By:	Approved By:	Date Created:	Date of Last Revision

Hazards Present:	PPE or Devices Required:	Additional Training Required:
Pinch Points	Gloves	
Crushing	Safety Glasses	
Wrenches slipping	Steel toed Boots	
Tire explosion		

## **Safe Work Procedure:**

- 1) Flammable materials (including propane bottle) is to be located a minimum of 50 feet from the front of the heater
- 2) All flammable materials (including propane bottle) is to be located a minimum of 10 feet from the sides, rear and top of the heater
- 3) The heater hose length should not be more than 50 feet
- 4) Extra hose is to be coiled and tied so that it is not a tripping hazard
- 5) Hose lying on the floor in traffic areas should be protected against puncture
- 6) Propane tanks must be stored in a well-ventilated and safe, secure place to prevent tipping or any other damage
- 7) Ensure there is sufficient space for the exhaust and ventilation of the heater

If an emergency situation occurs while conducting this task, or there is an equipment malfunction, engage the emergency stop and follow the lock out procedure

## REPORT ANY HAZARDOUS SITUATIONS TO YOUR SUPERVISOR

Guidance Documents/Standards:	This Safe Work Procedure will be reviewed any	
MB Workplace Safety & Health Act & Regulations:	time the task, equipment or materials change	
2.1 Safe Work Procedures	and at a minimum of every three years	
4 General Workplace Requirements	Reviewed By WSH Committee:	
6 Personal Protective Equipment		
35 WHMIS	Date:	
36 Chemical & Biological Substances		